

VERIFICATION OF CONFORMITY

No.: IN-XM-CP-5627-24109

Applicant: **OOO EGGER DREVPRODUKT GAGARIN**
Address: **EZHVINSKIY PROEZO, D. 1, RU-215010 SMOLENSK REGION, GAGARIN**

It has been verified that

Product(s): **EGGER PRO -EGGER HOME -EVER LAMINATE FLOORING**

Material: **HDF Boards + Balancer + Decor Paper + Overlay**

Product Specification: **8mm**

are submitted by the applicant to the testing of the product in accordance with ISO 16000-9:2006 /COR1-2007&ISO 16000-6:2021&ISO 16000-3:2022.

Based on the submitted sample(s), test was performed according to Decree 2011-321 relative to the labeling of construction products, floor or wall coverings and paints and lacquers concerning their emission of volatile pollutants, sample is A+ class.

on basis of the test report of **XMIN2406001069CM02_EN**.

The French A+ example logo is as follows



This verification is valid from Jul 26, 2024 until Jul 25, 2027 and remains valid as long as the manufacturing conditions in the plant or the factory production control itself are not modified significantly.

Issue 1. Verified since Jul 26, 2024

Authorised by




Manager

Industrial Services

SGS-CSTC Standards Technical Services Co., Ltd.

16F Century Yuhui Mansion No.73, Fucheng Road, Haidian District, Beijing, China 100142

email CN.CONSTProdcert@sgs.com website www.sgs.com



Disclaimer: Neither SGS-CSTC, any of its affiliated SGS sister organizations nor the SGS Group can be held responsible for conformity or non-conformity of the actual product with the contents of the Technical File. Copyright of this verification is owned by SGS-CSTC IND Services and may not be reproduced other than in full.

VERIFICATION OF CONFORMITY

No.: IN-XM-CP-5627-24109

..continued..

Results of examinations are as following:


Compound Name	CAS NO.	28 days result µg/m³	Classes requirements			
			C	B	A	A+
Formaldehyde	50-00-0	7.5	> 120	< 120	< 60	< 10
Acetaldehyde	75-07-0	11.4	> 400	< 400	< 300	< 200
Toluene	108-88-3	Not detected	> 600	< 600	< 450	< 300
Tetrachloroethylene	127-18-4	Not detected	> 500	< 500	< 350	< 250
Xylene	1330-20-7	Not detected	> 400	< 400	< 300	< 200
1,2,4- Trimethylbenzene	95-63-6	Not detected	> 2000	< 2000	< 1500	< 1000
1,4-Dichlorobenzene	106-46-7	Not detected	> 120	< 120	< 90	< 60
Ethylbenzene	100-41-4	Not detected	> 1500	< 1500	< 1000	< 750
2-Butoxyethanol	111-76-2	Not detected	> 2000	< 2000	< 1500	< 1000
Styrene	100-42-5	Not detected	> 500	< 500	< 350	< 250
TVOC	/	61.8	> 2000	< 2000	< 1500	< 1000

Conclusion: Based on the submitted sample(s), test was performed according to Decree 2011-321 relative to the labeling of construction products, floor or wall coverings and paints and lacquers concerning their emission of volatile pollutants, sample is A+ class.

Statement: Unless otherwise stated the results shown in this verification refer only to the sample(s) tested. The manufacturer is obligated to guarantee stability of product performance.

Issue 1. Verified since Jul 26, 2024

Authorised by



Manager
Industrial Services